



**Texas Department of State Health Services**

PO BOX 149347  
 AUSTIN, TEXAS 78714-9347  
 1-888-963-7111  
 www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947  
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

**Volatile Organic Compounds by GC/MS  
 Analysis Report**

Submitter Identification Number: 2460027

HIGH GABRIEL WSC  
 SPRINGER, DENNY  
 PO BOX 130  
 LEANDER, TX 78646-0130

Date Reported : 07/26/2016  
 Report ID# : 20160726044035AD45021

Lab Sample ID# : AD45021      Water Source :      Date Collected : 07/20/2016 09:19      Conc. Units : µg/L  
 Sample Priority : NORMAL      Entry Point(s) : EP001      Date Received : 07/21/2016      Method : EPA 524.2  
 TCEQ ID#(s) : 1603879      Date Analyzed : 07/22/2016      Analyst : LZ  
 Sample Cond. : Acceptable

Regulated Cmpds.[40 CFR 141.61(a)]	Result	Qualifier	Monitored Cmpds.[40 CFR 141.40(j)]	Result	Qualifier
Benzene <sup>1</sup>	<0.5		1,2,4-Trimethylbenzene	<1.0	
Carbon tetrachloride <sup>1</sup>	<0.5		1,2,3-Trichlorobenzene	<1.0	
Monochlorobenzene <sup>1</sup>	<0.5		n-Propylbenzene	<1.0	
o-Dichlorobenzene <sup>1</sup>	<0.5		n-Butylbenzene	<1.0	
para-Dichlorobenzene <sup>1</sup>	<0.5		Naphthalene	<1.0	
1,2-Dichloroethane <sup>1</sup>	<0.5		Hexachlorobutadiene	<1.0	
1,1-Dichloroethylene <sup>1</sup>	<0.5		1,3,5-Trimethylbenzene	<1.0	
cis-1,2-Dichloroethylene <sup>1</sup>	<0.5		4-Isopropyltoluene	<1.0	
trans-1,2-Dichloroethylene <sup>1</sup>	<0.5		Isopropylbenzene	<1.0	
1,2-Dichloropropane <sup>1</sup>	<0.5		t-Butylbenzene	<1.0	
Dichloromethane <sup>1</sup>	<0.5		s-Butylbenzene	<1.0	
Ethylbenzene <sup>1</sup>	<0.5		Trichlorofluoromethane	<2.0	
Styrene <sup>1</sup>	<0.5		Dichlorodifluoromethane	<2.0	
Tetrachloroethylene <sup>1</sup>	<0.5		Bromochloromethane	<1.0	
Toluene <sup>1</sup>	<0.5		<b>Other Compounds</b>	<b>Result</b>	<b>Qualifier</b>
1,2,4-Trichlorobenzene <sup>1</sup>	<0.5		Acetone	<10	
1,1,1-Trichloroethane <sup>1</sup>	<0.5		Acrylonitrile	<10	
1,1,2-Trichloroethane <sup>1</sup>	<0.5		2-Butanone (MEK)	<10	
Trichloroethylene <sup>1</sup>	<0.5		Carbon disulfide	<1.0	
Vinyl chloride <sup>1</sup>	<0.5		Ethyl methacrylate	<1.0	
Xylenes (total) <sup>1</sup>	<0.5		2-Hexanone	<1.0	
<b>Monitored Cmpds.[40 CFR 141.40(e)]</b>	<b>Result</b>	<b>Qualifier</b>	Iodomethane	<5.0	
Chloroform	<1.0		Methyl methacrylate	<1.0	
Bromodichloromethane	<1.0		4-Methyl-2-pentanone (MIBK)	<2.0	
Dibromochloromethane	<1.0		Methyl-t-butyl ether (MTBE)	<0.5	
Bromoform	<1.0		Tetrahydrofuran	<5.0	
Dibromomethane	<1.0		<b>Comments:</b>		
1,3-Dichlorobenzene	<1.0				
1,1-Dichloropropene	<1.0				
1,1-Dichloroethane	<1.0				
1,1,2,2-Tetrachloroethane	<1.0				
1,3-Dichloropropane	<1.0				
Chloromethane	<2.0				
Bromomethane	<2.0				
1,2,3-Trichloropropane	<1.0				
1,1,1,2-Tetrachloroethane	<1.0				
Chloroethane	<2.0				
2,2-Dichloropropane	<1.0				
2-Chlorotoluene	<1.0				
4-Chlorotoluene	<1.0				
Bromobenzene	<1.0				
cis-1,3-Dichloropropene	<1.0				
trans-1,3-Dichloropropene	<1.0				

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(!) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead KFREE on 07/25/2016