

LEAD & COPPER RULE MONITORING AND REPORTING VIOLATION  
MANDATORY LANGUAGE - TIER III

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

High Gabriel Water Supply, Inc. #2460027 has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section 290, Subchapter F. Even though these were not emergencies, as our customers, you have the right to know what happened and what we are doing (or did) to correct these situations.

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 1<sup>st</sup> quarter of 2013 through 4<sup>th</sup> quarter of 2013, we did not collect the mandatory five samples of water from five residents and test them for levels of copper and lead and therefore, cannot be sure of the quality of your drinking water during that time.*

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for [these contaminants], how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which the follow-up samples were [or will be] taken.

Contaminant	Required sampling frequency	Number of samples taken	When samples should have been taken	When samples were or will be taken
Lead & Copper tap water sampling	10 samples every three years	0 - 2013	June 1 – Sept 30, 2013	April 1 – June 30, 2015

**What is being done?**

We are working to correct the problem. For more information, please contact Denis D. Springer at [denisspringer@yahoo.com](mailto:denisspringer@yahoo.com)

**Corrective actions:**

A Corrective Action Procedure has been written to get our sampling in accordance with Chapter 30. We have also written a Standard Procedure that will assure that our samples are taken in June of each year with the testing and submission of results in July of each year.

*Please share this information with all other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by High Gabriel Water Supply, Inc. Our Public Water System Number: TX2460027

Date Distributed: 5/2/16