



Texas Department of State Health Services

PO BOX 149347
 AUSTIN, TEXAS 78714-9347
 1-888-963-7111
 www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

Volatile Organic Compounds by GC/MS Analysis Report

Submitter Identification Number: 2460027

HIGH GABRIEL WSC
 KREITER, AHARON
 PO BOX 2799
 CEDAR PARK, TX 78630-2799

Date Reported : 06/18/2020
 Report ID# : 20200618084708AF12734

Lab Sample ID# : AF12734	Water Source :	Date Collected : 05/27/2020 10:03	Conc. Units : µg/L
Sample Priority : NORMAL	Entry Point(s) : EP001	Date Received : 05/28/2020	Method : EPA 524.2
TCEQ ID#(s) : 2004159		Date Analyzed : 06/04/2020	Analyst : MA
			Sample Cond. : Acceptable

Regulated Cmpds.[40 CFR 141.61(a)]	Result	Qualifier	Monitored Cmpds.[40 CFR 141.40(j)]	Result	Qualifier
Benzene ¹	<0.5		1,2,4-Trimethylbenzene	<1.0	
Carbon tetrachloride ¹	<0.5		1,2,3-Trichlorobenzene	<1.0	
Monochlorobenzene ¹	<0.5		n-Propylbenzene	<1.0	
o-Dichlorobenzene ¹	<0.5		n-Butylbenzene	<1.0	
para-Dichlorobenzene ¹	<0.5		Naphthalene	<1.0	
1,2-Dichloroethane ¹	<0.5		Hexachlorobutadiene	<1.0	
1,1-Dichloroethylene ¹	<0.5		1,3,5-Trimethylbenzene	<1.0	
cis-1,2-Dichloroethylene ¹	<0.5		4-Isopropyltoluene	<1.0	
trans-1,2-Dichloroethylene ¹	<0.5		Isopropylbenzene	<1.0	
1,2-Dichloropropane ¹	<0.5		t-Butylbenzene	<1.0	
Dichloromethane ¹	<0.5		s-Butylbenzene	<1.0	
Ethylbenzene ¹	<0.5		Trichlorofluoromethane	<2.0	
Styrene ¹	<0.5		Dichlorodifluoromethane	<2.0	N
Tetrachloroethylene ¹	<0.5		Bromochloromethane	<1.0	
Toluene ¹	<0.5		Other Compounds	Result	Qualifier
1,2,4-Trichlorobenzene ¹	<0.5		Acetone	<10	
1,1,1-Trichloroethane ¹	<0.5		Acrylonitrile	<10	
1,1,2-Trichloroethane ¹	<0.5		2-Butanone (MEK)	<10	
Trichloroethylene ¹	<0.5		Carbon disulfide	<1.0	
Vinyl chloride ¹	<0.5		Ethyl methacrylate	<1.0	
Xylenes (total) ¹	<0.5		2-Hexanone	<1.0	
Monitored Cmpds.[40 CFR 141.40(e)]	Result	Qualifier	Iodomethane	<5.0	G
Chloroform	<1.0		Methyl methacrylate	<1.0	
Bromodichloromethane	<1.0		4-Methyl-2-pentanone (MIBK)	<2.0	
Dibromochloromethane	<1.0		Methyl-t-butyl ether (MTBE)	<0.5	
Bromoform	1.0		Tetrahydrofuran	<5.0	
Dibromomethane	<1.0		Comments:		
1,3-Dichlorobenzene	<1.0		N - See sample comments.		
1,1-Dichloropropene	<1.0		G - CCV/LFB recovery was below method acceptance limits.		
1,1-Dichloroethane	<1.0		EPA method 524.2 --- Dichlorodifluoromethane and		
1,1,2,2-Tetrachloroethane	<1.0		Chloromethane CCV/LFB recoveries were above method		
1,3-Dichloropropane	<1.0		acceptance limits. These target analytes were not detected		
Chloromethane	<2.0	N	inthe sample. The test results on this report relate only to the		
Bromomethane	<2.0		sample identified on this report. The test results for analytes		
1,2,3-Trichloropropane	<1.0		noted(1) meet all TNI (2009 Standard) requirements.		
1,1,1,2-Tetrachloroethane	<1.0		Authorized by Group Manager TDUNN on 06/17/2020		
Chloroethane	<2.0				
2,2-Dichloropropane	<1.0				
2-Chlorotoluene	<1.0				
4-Chlorotoluene	<1.0				
Bromobenzene	<1.0				
cis-1,3-Dichloropropene	<1.0				
trans-1,3-Dichloropropene	<1.0				