

High Gabriel Water Supply Customers,

High Gabriel WSC failed to report on time the collected required daily samples for disinfectant residual monitoring of the water entering the distribution system for 1Q, 2Q, 3Q and 4Q of 2013. This monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523. Failure to report makes it impossible for the Texas Commission on Environmental Quality (TCEQ) to know if there is the required minimum disinfectant residual requirement of .2 mg/l (ppm) of chlorine. Our water system is required to take a disinfectant residual sample once each day. Failure to report accordingly is a violation of the monitoring requirements and we are required to notify you of this violation. If you have any questions regarding this violation, you may contact Terry Tuttle at tatuttle@texaswater.net.

Regards,

Denis D. Springer

President HGWSC